



Installation and Maintenance Requirements

Big Foot Systems recommend that all frameworks are placed on the roof membrane with suitable sacrificial layer as required where practical, where this is not possible engineering advice should be sought. Big Foot Systems recommend that all roof top products are installed by suitably qualified persons. A qualified installer should have professional knowledge regarding compliance with Health and Safety, Local Regulations and Industry standards. The choice of the installation location, product orientation, evaluation of the roof structure, composition and surface should also be taken into consideration, along with the choice of ancillary and complimentary products and materials. Appropriate tools and materials for installation and for the ongoing maintenance of all Big Foot System products should be selected. Consideration in respect of the application of Big Foot System products should also be given procedures in respect of known climatic conditions during installation and use.

Material Grade: BS EN 10219-1:1997 (S235JR)
Welding Standard: BS EN ISO 15614-1
Galvanizing Standard: BS EN ISO 1461:1999

DIMENSIONS ARE IN MILLIMETERS TOLERANCES: 0.0 ± 0.5 0.00 ± 0.25	DEBUR AND BREAK SHARP EDGES	MATERIAL: SEE NOTES FINISH: SEE NOTES	TITLE: BIG FOOT 2 M SYSTEM
DRAWN BY: JAMES ALCOCK	DRAWN DATE: 18/10/2011	DWG NO: B9443	REVISION: A
SCALE: 1:20 DO NOT SCALE DRAWING SHEET 1 OF 2			A3

